

VOC Content Test Certificate

Wednesday 23rd March 2022

Supplier: Parchem Construction Supplies Pty Ltd (7 Lucca Road, Wyong, NSW, 2259, Australia)

Product Description: Fosroc NitoFlor PU200

Date Tested: March 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings Materials. ASTM D3960 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Fosroc NitoFlor PU200
One and Two Pack Performance Coatings for Floors: 140 grams per Liter	31 grams per Liter as VOC content per material
<i>We hereby certify that Fosroc NitoFlor PU200 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

P22020124_Ver1