

VOC Content Test Certificate

Monday 22nd July 2024

Supplier: Dulux Australia Pty Ltd (1956 Dandenong Road, Clayton, VIC, 3168, AUSTRALIA).
Product name: Nitoflor FC150 HP-SL
Date Tested: July 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	Nitoflor FC150 HP-SL
One and Two Pack Performance Coatings for Floors Limit: 140 grams per litre	14 grams per litre as VOC content per material
<i>We hereby certify Nitoflor FC150 HP-SL is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 22/07/2024

Expiry date: 22/07/2029

P24070030